



UNITED STATES PATENT AND TRADEMARK OFFICE

UNITED STATES DEPARTMENT OF COMMERCE
United States Patent and Trademark Office
Address: COMMISSIONER FOR PATENTS
P.O. Box 1450
Alexandria, Virginia 22313-1450
www.uspto.gov

APPLICATION NO.	FILING DATE	FIRST NAMED INVENTOR	ATTORNEY DOCKET NO.	CONFIRMATION NO.
10/798,215	03/11/2004	Lawrence M. Janesky	257-011583-US(PAR)	6120
2512	7590	06/03/2008		
PERMAN & GREEN 425 POST ROAD FAIRFIELD, CT 06824			EXAMINER DREIDAME, HUNTER M	
			ART UNIT	PAPER NUMBER
			3633	
			MAIL DATE	DELIVERY MODE
			06/03/2008	PAPER

Please find below and/or attached an Office communication concerning this application or proceeding.

The time period for reply, if any, is set in the attached communication.

Office Action Summary	Application No. 10/798,215	Applicant(s) JANESKY, LAWRENCE M.	
	Examiner HUNTER M. DREIDAME	Art Unit 3633	

-- The MAILING DATE of this communication appears on the cover sheet with the correspondence address --

Period for Reply

A SHORTENED STATUTORY PERIOD FOR REPLY IS SET TO EXPIRE 3 MONTH(S) OR THIRTY (30) DAYS, WHICHEVER IS LONGER, FROM THE MAILING DATE OF THIS COMMUNICATION.

- Extensions of time may be available under the provisions of 37 CFR 1.136(a). In no event, however, may a reply be timely filed after SIX (6) MONTHS from the mailing date of this communication.
- If NO period for reply is specified above, the maximum statutory period will apply and will expire SIX (6) MONTHS from the mailing date of this communication.
- Failure to reply within the set or extended period for reply will, by statute, cause the application to become ABANDONED (35 U.S.C. § 133). Any reply received by the Office later than three months after the mailing date of this communication, even if timely filed, may reduce any earned patent term adjustment. See 37 CFR 1.704(b).

Status

- 1) ☒ Responsive to communication(s) filed on 8/31/2007.
- 2a) ☒ This action is **FINAL**. 2b) ☐ This action is non-final.
- 3) ☐ Since this application is in condition for allowance except for formal matters, prosecution as to the merits is closed in accordance with the practice under *Ex parte Quayle*, 1935 C.D. 11, 453 O.G. 213.

Disposition of Claims

- 4) ☒ Claim(s) 1-15 is/are pending in the application.
- 4a) Of the above claim(s) _____ is/are withdrawn from consideration.
- 5) ☐ Claim(s) _____ is/are allowed.
- 6) ☒ Claim(s) 1-6 and 12 is/are rejected.
- 7) ☒ Claim(s) 7-11, 13-15 is/are objected to.
- 8) ☐ Claim(s) _____ are subject to restriction and/or election requirement.

Application Papers

- 9) ☐ The specification is objected to by the Examiner.
- 10) ☐ The drawing(s) filed on _____ is/are: a) ☐ accepted or b) ☐ objected to by the Examiner.
Applicant may not request that any objection to the drawing(s) be held in abeyance. See 37 CFR 1.85(a).
Replacement drawing sheet(s) including the correction is required if the drawing(s) is objected to. See 37 CFR 1.121(d).
- 11) ☐ The oath or declaration is objected to by the Examiner. Note the attached Office Action or form PTO-152.

Priority under 35 U.S.C. § 119

- 12) ☐ Acknowledgment is made of a claim for foreign priority under 35 U.S.C. § 119(a)-(d) or (f).
- a) ☐ All b) ☐ Some * c) ☐ None of:
1. ☐ Certified copies of the priority documents have been received.
 2. ☐ Certified copies of the priority documents have been received in Application No. _____.
 3. ☐ Copies of the certified copies of the priority documents have been received in this National Stage application from the International Bureau (PCT Rule 17.2(a)).

* See the attached detailed Office action for a list of the certified copies not received.

Attachment(s)

- | | |
|--|---|
| 1) <input type="checkbox"/> Notice of References Cited (PTO-892) | 4) <input type="checkbox"/> Interview Summary (PTO-413) |
| 2) <input type="checkbox"/> Notice of Draftsperson's Patent Drawing Review (PTO-948) | Paper No(s)/Mail Date. _____ |
| 3) <input type="checkbox"/> Information Disclosure Statement(s) (PTO/SB/08) | 5) <input type="checkbox"/> Notice of Informal Patent Application |
| Paper No(s)/Mail Date _____ | 6) <input type="checkbox"/> Other: _____ |


DETAILED ACTION

Claim Rejections - 35 USC § 102

(b) the invention was patented or described in a printed publication in this or a foreign country or in public use or on sale in this country, more than one year prior to the date of application for patent in the United States.

Claims 1, 3, and 12 are rejected under 35 U.S.C. 102(b) as being anticipated by US Patent 6,279,279 to Larimore.

LARIMORE discloses a water drainage system including continuous embossed plastic drainage panel (60,72) to define a continuous barrier preventing water and water vapor penetration, column 8, lines 16-24 and column 9, lines 18-38, having a plurality of spaced embossments (62) on an underside thereof to allow for drainage. In reference to claim 3, the drainage system is provided in a crawlspace (CS) having a concrete floor (70). Regarding claim 12, a plastic foam (72) is provided over the embossed drainage panel (60).



Claim Rejections - 35 USC § 103

The following is a quotation of 35 U.S.C. 103(a) which forms the basis for all obviousness rejections set forth in this Office action:

(a) A patent may not be obtained though the invention is not identically disclosed or described as set forth in section 102 of this title, if the differences between the subject matter sought to be patented and the prior art are such that the subject matter as a whole would have been obvious at the time the invention was made to a person having ordinary skill in the art to which said subject matter pertains. Patentability shall not be negated by the manner in which the invention was made.

Claim 2 is rejected under 35 U.S.C. 103(a) as being unpatentable over US Patent 6,279,279 to Larimore in view of US Patent 4,907,386 to Ekroth.

LARIMORE discloses the basic claimed invention except for having the drainage panel

extend up vertically adjacent the vertical walls of the foundation. EKROTH teaches that it is known in the art to extend a drainage sheet (20) vertically as shown in figures 7-9. Thus it would have been obvious to one having ordinary skill in the art to extend the drainage sheet of LARIMORE vertically, as taught by EKROTH, in order to fully protect the foundation walls. If the sheet is only positioned on the foundation floor, if water or vapors enter the space the wall are not protected. However, if the sheet is allowed to be positioned adjacent the wall of the foundation also, then the foundation in its entirety is protected.

Claims 4-6 stands rejected under 35 U.S.C. 103(a) as being unpatentable over US Patent #6,279,279 to LARIMORE in view of US Patent #5,931,603 to SWAIN et al. LARIMORE discloses the basic claimed structure except for the foundation being formed of dirt with a peripheral trench. Forming a foundation out of dirt and having a peripheral trench is old and very well known in the art. However, SWAIN et al. teaches that it is known to provide a structure with a dirt foundation (102) with a trench (72) and

Art Unit: 3635

sump pump (80) positioned therein. Thus it would have been obvious to one having ordinary skill in the art at the time the invention was made to provide the system of a

LARIMORE with a trench and sump pump, as taught by SWAIN et al., in order to ensure that potential exposure to or backflow of water does not occur.

Response to Arguments

Applicant's arguments with respect to claims 1-6 and 12 have been considered but are moot in view of the new ground(s) of rejection.

Conclusion

THIS ACTION IS MADE FINAL. Applicant is reminded of the extension of time policy as set forth in 37 CFR 1.136(a).

A shortened statutory period for reply to this final action is set to expire THREE MONTHS from the mailing date of this action. In the event a first reply is filed within TWO MONTHS of the mailing date of this final action and the advisory action is not mailed until after the end of the THREE-MONTH shortened statutory period, then the shortened statutory period will expire on the date the advisory action is mailed, and any extension fee pursuant to 37 CFR 1.136(a) will be calculated from the mailing date of the advisory action. In no event, however, will the statutory period for reply expire later than SIX MONTHS from the mailing date of this final action.

Any inquiry concerning this communication or earlier communications from the examiner should be directed to HUNTER M. DREIDAME whose telephone number is (571)272-5177. The examiner can normally be reached on Monday - Friday 8am - 5pm.

If attempts to reach the examiner by telephone are unsuccessful, the examiner's supervisor, Robert Canfield can be reached on (571)272-6840. The fax phone number for the organization where this application or proceeding is assigned is 571-273-8300.

Information regarding the status of an application may be obtained from the Patent Application Information Retrieval (PAIR) system. Status information for published applications may be obtained from either Private PAIR or Public PAIR. Status information for unpublished applications is available through Private PAIR only. For more information about the PAIR system, see <http://pair-direct.uspto.gov>. Should you have questions on access to the Private PAIR system, contact the Electronic Business Center (EBC) at 866-217-9197 (toll-free). If you would like assistance from a USPTO Customer Service Representative or access to the automated information system, call 800-786-9199 (IN USA OR CANADA) or 571-272-1000.

/Richard E. Chilcot/
Supervisory Patent Examiner, Art
Unit 3635

/Hunter M Dreidame/
Examiner, Art Unit 3633